

AMERICAN NATIONAL STANDARD

ANSI/ISA-18.2-2016

**Management of Alarm Systems
for the Process Industries**

Approved 17 March 2016

ANSI/ISA-18.2-2016
Management of Alarm Systems for the Process Industries

ISBN: 978-1-941546-86-4

Copyright © 2016 by the International Society of Automation. All rights reserved. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written permission of the publisher.

ISA
67 Alexander Drive
P.O. Box 12277
Research Triangle Park, North Carolina 27709
E-mail: standards@isa.org

Preface

This preface as well as all footnotes, annexes, and draft technical reports associated with this standard are included for information purposes only and are not part of ANSI/ISA-18.2-2016.

This standard has been prepared as part of the service of ISA, the International Society of Automation, toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA, 67 Alexander Drive; P.O. Box 12277; Research Triangle Park, NC 277099; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

This ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards, recommended practices, and technical reports. The Department is further aware of the benefits of USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, the Department will endeavor to introduce SI and acceptable metric units in all new and revised standards to the greatest extent possible. The Metric Practice Guide, which has been published by the Institute of Electrical and Electronics Engineers (IEEE) as ANSI/IEEE Std. 268-1992, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

This standard is structured to follow the IEC guidelines. Therefore, the first three sections discuss the *Scope* of the standard, *Normative References* and *Definitions*, in that order.

CAUTION — ISA ADHERES TO THE POLICY OF THE AMERICAN NATIONAL STANDARDS INSTITUTE WITH REGARD TO PATENTS. IF ISA IS INFORMED OF AN EXISTING PATENT THAT IS REQUIRED FOR USE OF THE STANDARD, IT WILL REQUIRE THE OWNER OF THE PATENT TO EITHER GRANT A ROYALTY-FREE LICENSE FOR USE OF THE PATENT BY USERS COMPLYING WITH THE STANDARD OR A LICENSE ON REASONABLE TERMS AND CONDITIONS THAT ARE FREE FROM UNFAIR DISCRIMINATION.

EVEN IF ISA IS UNAWARE OF ANY PATENT COVERING THIS STANDARD, THE USER IS CAUTIONED THAT IMPLEMENTATION OF THE STANDARD MAY REQUIRE USE OF TECHNIQUES, PROCESSES, OR MATERIALS COVERED BY PATENT RIGHTS. ISA TAKES NO POSITION ON THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS THAT MAY BE INVOLVED IN IMPLEMENTING THE STANDARD. ISA IS NOT RESPONSIBLE FOR IDENTIFYING ALL PATENTS THAT MAY REQUIRE A LICENSE BEFORE IMPLEMENTATION OF THE STANDARD OR FOR INVESTIGATING THE VALIDITY OR SCOPE OF ANY PATENTS BROUGHT TO ITS ATTENTION. THE USER SHOULD CAREFULLY INVESTIGATE RELEVANT PATENTS BEFORE USING THE STANDARD FOR THE USER'S INTENDED APPLICATION.

HOWEVER, ISA ASKS THAT ANYONE REVIEWING THIS STANDARD WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE STANDARD NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER. ADDITIONALLY, THE USE OF THIS STANDARD MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE STANDARD CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS STANDARD MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE

USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS STANDARD.

THE USER OF THIS DOCUMENT SHOULD BE AWARE THAT THIS DOCUMENT MAY BE IMPACTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT YET ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.

The following people served as voting members of ISA18 and approved this standard on 7 December 2015:

NAME	COMPANY
D. Dunn, Co-Chair	Consultant
N. Sands, Co-Chair	DuPont
B. Fitzpatrick, Managing Director	Wood Group Mustang
J. Alford	Consultant
S. Apple	Schneider Electric
J. Bogdan	J Bogdan Consulting LLC
K. Brown	Enbridge Inc.
M. Brown	Matrikon Inc.
A. Bryant	Oxy Inc.
J. Campbell	Consultant
M. Carter	SIS-TECH Solutions
L. Dubois	UReason
B. Hollifield	PAS
S. Kandasamy	Chevron Energy Technology Company
D. Logerot	ProSys Inc.
C. Lundy	Suncor
M. Marvan	Shell Canada
D. Metzger	DPM Consulting
L. Myers	Consultant
G. Nasby	City of Guelph Water Services
G. Plowman	Rockwell Automation
D. Rothenberg	D Roth Inc.
T. Stauffer	Exida Co.
D. Strobhar	Beville Engineering Inc.
B. Vail	URS PS / AECOM
K. Van Camp	Emerson Process Management
D. Visnich	Burns & McDonnell
R. Weibel	Tips Inc.

This published standard was approved for publication by the ISA Standards and Practices Board on 7 March 2016.

NAME	COMPANY
N. Sands, Vice President	DuPont
D. Bartusiak	ExxonMobil Research & Engineering
P. Brett	Honeywell Inc.
E. Cosman	OIT Concepts, LLC
D. Dunn	Consultant
J. Federlein	Federlein & Assoc. LLC
B. Fitzpatrick	Wood Group Mustang
J. Gilsinn	Kenexis Consulting
J.-P. Hauet	KB Intelligence
J. Jamison	Encana Corp.

D. Lee
K.-P. Lindner
T. McAviney
V. Mezzano
C. Monchinski
D. Reed
H. Sasajima
T. Schnaare
J. Tatera
K. Unger
I. Verhappen
D. Visnich
W. Weidman
J. Weiss
M. Wilkins
D. Zetterberg

UCDS
Endress+Hauser Process Solutions AG
Consultant
Fluor Corp.
Automated Control Concepts Inc.
Rockwell Automation
Azbil Corp.
Rosemount Inc.
Tatera & Associates Inc.
Consultant
Industrial Automation Networks
Burns & McDonnell
Consultant
Applied Control Solutions LLC
Yokogawa
Chevron Energy

This page intentionally left blank.

CONTENTS

Introduction	11
1 Scope	13
1.1 General applicability	13
1.2 Exclusions and inclusions	14
2 Normative references	15
3 Terms, definitions, and acronyms	15
3.1 Terms and definitions	15
3.2 Abbreviations	25
4 Conformance to this standard	25
4.1 Conformance guidance	25
4.2 Existing systems	25
4.3 Use of required functionalities	26
4.4 Responsibility	26
5 Alarm system models	26
5.1 Alarm systems	26
5.2 Alarm management lifecycle	26
5.3 Alarm states	31
5.4 Alarm response timeline	35
5.5 Feedback model of operator – process interaction	37
6 Alarm philosophy	38
6.1 Purpose	38
6.2 Alarm philosophy contents	38
6.3 Alarm philosophy development and maintenance	44
7 Alarm system requirements specification	45
7.1 Purpose	45
7.2 Recommendations	45
7.3 Development	45
7.4 Systems evaluation	46
7.5 Packaged systems	46
7.6 Customization	46
7.7 Alarm system requirements testing	46
8 Identification	46
8.1 Purpose	46
8.2 Alarm identification methods	46
8.3 Identification training	47
8.4 Identification documentation	47
9 Rationalization	47
9.1 Purpose	47
9.2 Rationalization documentation	47
9.3 Alarm justification	48
9.4 Alarm setpoint determination	49
9.5 Prioritization	49

9.6	Classification	49
9.7	Review.....	50
9.8	Removal of rejected alarms	50
9.9	Documentation	50
10	Detailed design: basic alarm design.....	50
10.1	Purpose	50
10.2	Basic alarm design capabilities.....	50
10.3	Usage of alarm states	50
10.4	Alarm types.....	51
10.5	Alarm attributes.....	51
10.6	Programmatic changes to alarm attributes	53
10.7	Review basic alarm design	53
11	Detailed design: human-machine interface design for alarm systems.....	53
11.1	Purpose	53
11.2	HMI functions.....	53
11.3	Alarm states indications	54
11.4	Alarm priority indications	56
11.5	Alarm message indications	57
11.6	Alarm displays.....	57
11.7	Alarm shelving	60
11.8	Out-of-service alarms	61
11.9	Alarms suppressed by design	62
11.10	Alarm annunciator integration	63
11.11	Safety alarm HMI	64
12	Detailed design: enhanced and advanced alarm methods.....	64
12.1	Purpose	64
12.2	Basis of enhanced and advanced alarming	64
12.3	Information linking.....	65
12.4	Logic-based alarming	65
12.5	Model-based alarming.....	65
12.6	Additional alarming considerations.....	66
12.7	Training, testing, and auditing systems	67
12.8	Alarm attribute enforcement.....	67
13	Implementation	67
13.1	Purpose	67
13.2	Implementation planning.....	67
13.3	Implementation training	67
13.4	Implementation testing and validation	68
13.5	Implementation documentation	69
14	Operation.....	70
14.1	Purpose	70
14.2	Alarm response procedures	70
14.3	Alarm shelving	70
14.4	Refresher training for operators	71

- 15 Maintenance 71
 - 15.1 Purpose 71
 - 15.2 Periodic alarm testing..... 72
 - 15.3 Out-of-service alarms 72
 - 15.4 Equipment repair 73
 - 15.5 Equipment replacement..... 73
 - 15.6 Refresher training for maintenance 73
- 16 Monitoring and assessment 74
 - 16.1 Purpose 74
 - 16.2 Performance monitoring 74
 - 16.3 Monitoring and assessment 74
 - 16.4 Alarm system performance metrics 74
 - 16.5 Unauthorized alarm suppression..... 77
 - 16.6 Alarm attribute monitoring 77
 - 16.7 Reporting of alarm system analyses 77
 - 16.8 Alarm performance metric summary..... 78
- 17 Management of change 78
 - 17.1 Purpose 78
 - 17.2 Changes subject to management of change 78
 - 17.3 Change documentation requirements 79
 - 17.4 Alarm removal recommendations 79
 - 17.5 Alarm attribute modification recommendations 79
- 18 Audit..... 79
 - 18.1 Purpose 79
 - 18.2 Benchmark..... 79
 - 18.3 Audit interviews..... 80
 - 18.4 Audit recommendations 80
 - 18.5 Action plans 80
- 19 Bibliography 80

Figures

Figure 1 – Alarm system dataflow 13
Figure 2 – Alarm management lifecycle..... 27
Figure 3 - Alarm state transition diagram..... 32
Figure 4 - Alarm response timeline..... 35
Figure 5 - Feedback model of operator process interaction 37

Tables

Table 1 - Alarm management lifecycle stage inputs and outputs 31
Table 2 - Alarm states 33
Table 3 - Required and recommended alarm philosophy content 39
Table 4 - Recommended alarm state indications 56
Table 5 - Average alarm rates..... 75
Table 6 – Example annunciated alarm priority distribution 77
Table 7 – Recommended alarm performance metrics summary..... 78

Introduction

Purpose

This standard addresses the development, design, installation, and management of alarm systems in the process industries. Alarm management includes multiple work processes throughout the alarm management lifecycle. This standard defines the terminology and models to develop an alarm system, and it defines the work processes recommended to effectively maintain the alarm system throughout the lifecycle.

This standard was written as an extension of existing ISA standards with due consideration of other guidance documents that have been developed throughout industry. Ineffective alarm systems have often been cited as contributing factors in the investigation reports following major process incidents. This standard is intended to provide a methodology that will result in the improved safety, quality, and operation in the process industries.

This standard is not the first effort to define terminology and practices for effective alarm systems. In 1955 ISA formed a survey committee titled Instrument Alarms and Interlocks. The committee evolved to Standard & Practices Committee 18. In 1965 the committee completed ISA-RP18.1, *Specifications and Guides for the Use of General Purpose Annunciators*. In 1979 ISA released, as a product of the ISA18 and ISA67 committees, ISA-18.1-1979 (R2004), *Annunciator Sequences and Specifications*. In 1994 Amoco, Applied Training Resources, BP, Exxon, Gensym, Honeywell, Mobil, Novacor, Texaco, Shell, and others formed the Abnormal Situation Management Consortium (ASM) to develop a vision for better response to process incidents, with additional support in 1994 from the U.S. National Institute of Standards and Technology (NIST). In 1999 the Engineering Equipment and Materials Users' Association (EEMUA) issued Publication 191, *Alarm Systems: A Guide to Design, Management and Procurement*, which was updated in 2007, and again in 2013. In 2003 the User Association of Process Control Technology in Chemical and Pharmaceutical Industries (NAMUR) issued recommendation NA 102, *Alarm Management*. This ISA standard was originally issued in 2009, and International Electrotechnical Commission (IEC) developed IEC 62682 from that version and issued it in 2014.

During the development and maintenance of this standard every effort was made to keep terminology and practices consistent with the previous work of these respected organizations and committees.

This document provides requirements for alarm management and alarm systems. It is intended for those individuals and organizations that

- a) manufacture or implement embedded alarm systems,
- b) manufacture or implement third-party alarm system software,
- c) design or implement alarm systems,
- d) operate and maintain alarm systems, and
- e) audit or assess alarm system performance.

Organization

This standard is organized in two parts. The first part is introductory in nature, (Clauses 1 to 5). The main body of the standard follows (Clauses 6 to 18), which presents mandatory requirements and non-mandatory recommendations as noted.