

RECOMMENDED PRACTICE

ISA-RP105.00.01-2017

**Management of a Calibration Program for
Industrial Automation and Control Systems**

Approved Date – 24 May 2017

ISA-RP105.00.01-2017, Management of a Calibration Program for Industrial Automation and Control Systems

ISBN: 978-1-945541-63-6

Copyright © 2017 by the International Society of Automation (ISA). Not for resale. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic mechanical, photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA
67 T.W. Alexander Drive
P.O. Box 12277
Research Triangle Park, North Carolina 27709

Preface

This preface, as well as all footnotes and annexes, is included for information purposes and is not part of ISA-RP105.00.01-2017.

This document has been prepared as part of the service of ISA toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 T.W. Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. *Standard for Use of the International System of Units (SI): The Modern Metric System*, published by the American Society for Testing & Materials as IEEE/ASTM SI 10-97, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

CAUTION — ISA DOES NOT TAKE ANY POSITION WITH RESPECT TO THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS ASSERTED IN CONNECTION WITH THIS DOCUMENT, AND ISA DISCLAIMS LIABILITY FOR THE INFRINGEMENT OF ANY PATENT RESULTING FROM THE USE OF THIS DOCUMENT. USERS ARE ADVISED THAT DETERMINATION OF THE VALIDITY OF ANY PATENT RIGHTS, AND THE RISK OF INFRINGEMENT OF SUCH RIGHTS, IS ENTIRELY THEIR OWN RESPONSIBILITY.

PURSUANT TO ISA'S PATENT POLICY, ONE OR MORE PATENT HOLDERS OR PATENT APPLICANTS MAY HAVE DISCLOSED PATENTS THAT COULD BE INFRINGED BY USE OF THIS DOCUMENT AND EXECUTED A LETTER OF ASSURANCE COMMITTING TO THE GRANTING OF A LICENSE ON A WORLDWIDE, NON-DISCRIMINATORY BASIS, WITH A FAIR AND REASONABLE ROYALTY RATE AND FAIR AND REASONABLE TERMS AND CONDITIONS. FOR MORE INFORMATION ON SUCH DISCLOSURES AND LETTERS OF ASSURANCE, CONTACT ISA OR VISIT WWW.ISA.ORG/STANDARDSPATENTS.

OTHER PATENTS OR PATENT CLAIMS MAY EXIST FOR WHICH A DISCLOSURE OR LETTER OF ASSURANCE HAS NOT BEEN RECEIVED. ISA IS NOT RESPONSIBLE FOR IDENTIFYING PATENTS OR PATENT APPLICATIONS FOR WHICH A LICENSE MAY BE REQUIRED, FOR CONDUCTING INQUIRIES INTO THE LEGAL VALIDITY OR SCOPE OF PATENTS, OR DETERMINING WHETHER ANY LICENSING TERMS OR CONDITIONS PROVIDED IN CONNECTION WITH SUBMISSION OF A LETTER OF ASSURANCE, IF ANY, OR IN ANY LICENSING AGREEMENTS ARE REASONABLE OR NON-DISCRIMINATORY.

ISA REQUESTS THAT ANYONE REVIEWING THIS DOCUMENT WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE DOCUMENT NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.

ADDITIONALLY, THE USE OF THIS DOCUMENT MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE DOCUMENT CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS DOCUMENT MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS DOCUMENT.

THE USER OF THIS DOCUMENT SHOULD BE AWARE THAT THIS DOCUMENT MAY BE IMPACTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT YET ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.

ISA (www.isa.org) is a nonprofit professional association that sets the standard for those who apply engineering and technology to improve the management, safety, and cybersecurity of modern automation and control systems used across industry and critical infrastructure. Founded in 1945, ISA develops widely used global standards; certifies industry professionals; provides education and training; publishes books and technical articles; hosts conferences and exhibits; and provides networking and career development programs for its 40,000 members and 400,000 customers around the world.

ISA owns Automation.com, a leading online publisher of automation-related content, and is the founding sponsor of The Automation Federation (www.automationfederation.org), an association of non-profit organizations serving as "The Voice of Automation." Through a wholly owned subsidiary, ISA bridges the gap between standards and their implementation with the ISA Security Compliance Institute (www.isasecure.org) and the ISA Wireless Compliance Institute (www.isa100wci.org).

The following served as voting members on the ISA105 committee:

NAME	COMPANY
J. Federlein, Chair	Federlein & Assoc. LLC
P. Brett, Managing Director	Honeywell Inc.
J. Jamison	Jamison & Associates Ltd.
G. Lehmann	AECOM
T. McAviney	Consultant
G. Ramachandran	Systems Research International Inc.
L. Staples	Oklahoma Gas & Electric
I. Verhappen	Industrial Automation Networks

The following served as members of the Standards and Practices Board and approved the document on 24 March 2017:

NAME	COMPANY
M. Wilkins, Vice President	Yokogawa
D. Bartusiak	ExxonMobil Research & Engineering
D. Brandl	BR&L Consulting
P. Brett	Honeywell Inc.
E. Cosman	OIT Concepts, LLC
D. Dunn	Consultant
J. Federlein	Federlein & Assoc. LLC
B. Fitzpatrick	Wood Group Mustang
J. Gilsinn	Kenexis Consulting
J.-P. Hauet	KB Intelligence
D. Lee	UCDS
G. Lehmann	AECOM

K.-P. Lindner
T. McAviney
V. Mezzano
C. Monchinski
G. Nasby
M. Nixon
D. Reed
N. Sands
H. Sasajima
H. Storey
K. Unger
I. Verhappen
D. Visnich
W. Weidman
J. Weiss
D. Zetterberg

Endress+Hauser Process Solutions AG
Consultant
Fluor Corp.
Automated Control Concepts Inc.
City of Guelph Water Services
Emerson Process Management
Rockwell Automation
DuPont
Fieldcomm Group Inc. Asia-Pacific
Herman Storey Consulting
Consultant
Industrial Automation Networks
Burns & McDonnell
Consultant
Applied Control Solutions LLC
Chevron Energy

This page intentionally left blank.

Table of Contents

- Introduction 9
 - Purpose 9
 - Organization 10
- 1 Scope 11
 - 1.1 General applicability 11
 - 1.2 Inclusions and exclusions 11
- 2 References 11
- 3 Definition of terms and acronyms 12
 - 3.1 Terms 12
 - 3.2 Acronyms 15
- 4 Establishing a calibration program 15
 - 4.1 General 15
 - 4.2 Calibration program concepts 16
 - 4.3 Calibration program 16
 - 4.4 Device calibration 16
 - 4.5 Loop calibration 16
 - 4.6 Competency 17
- 5 Calibration program planning 17
 - 5.1 General 17
 - 5.2 Loops and components in the calibration program 18
 - 5.3 Component and loop criticality determination 18
 - 5.4 Establishing required loop tolerance 18
 - 5.5 Calculating theoretical loop tolerance 18
 - 5.6 Calibration confirmation intervals 19
 - 5.7 Calibration equipment 20
 - 5.8 Calibration record system 21
 - 5.9 Calibration procedures 22
 - 5.10 Calibration personnel 22
 - 5.11 Responsibilities 23
- 6 Loop and component performance verification 24
 - 6.1 General 24
- 7 Calibration program management 24
 - 7.1 Control 24
 - 7.2 Assurance 24
 - 7.3 Improvement 24
- 8 Examples 25
 - 8.1 Example 1 – Calculating instrument total error 25
 - 8.2 Example 2 – Calculating theoretical loop tolerance 26
 - 8.3 Example 3 – Pressure measurement theoretical loop tolerance – pressure switch 27
 - 8.4 Example 4 – Pressure measurement theoretical tolerance – pressure gauge 28
 - 8.5 Example 5 – Calculating calibration accuracy 28

8.6	Example 6 – Calculating calibration TUR	29
Annex A	– Example documentation	31
A.1	On-line testing procedure of differential pressure transmitter	31
A.2	Differential pressure (DP) calibration task list (HART transmitter)	33
A.3	Calibration service record example form	35